

BLADE TYPE D. E. PRODUCT SPECIFICATION

The media is to be manufactured by Brentwood Industries, or equal and will meet the following specifications:

1. Scope:

ACCU-PAC $_{O}$ DE-120 blade type drift eliminator designed to remove entrained water droplets from the leaving air stream at minimum pressure losses in either counter-flow or cross-flow cooling towers.

2. Material of Construction:

A. General

The drift modules shall be fabricated from rigid, corrugated PVC sheets that are conducive to cooling water and UV protected. The drift modules shall be resistant to rot, fungi, bacteria and inorganic/organic acids and alkalies as commonly found in cooling towers.

B. PVC SHEETS

The PVC sheet shall be prime, rigid PVC conforming to commercial standard ASTM D1784:12344B to 12454B with the following properties:

PROPERTY	TEST METHOD	UNIT	TYPICAL VALUE
Specific Gravity	D-792	gm./cu.cm.	1.45 max.
Tensile Strength	D-638/D-882	psi	6000 min.
Flexural Modulus	D-790	psi	425,000 min.
Flexural Strength	D-790	psi	10,000 min.
Elastic Modulus	D-638/D-882	psi	360,000 min.
Izod Impact	D-256	ft.lbs./in.	1.0 min.
Impact Resistance	D-4226	in. lbs./mil	0.8 min.
Heat Deflection	D-648	°F(264 psi)	160 min.
Flame Spread Rating	E-84		Less than 15
Flammability	D-635		Self-extinguishing, less than 5 sec.

					MAD	THIS DRAWING IS THE SOLE PROPERTY OF COOLING TOWER DEPOT INC. USE SHALL BE LIMITED TO THE PROJECT FOR WHICH IT IS INTENDED. NO REPRODUCTION SHALL BE MADE NOR SHALL THIS INFORMATION BE MADE AVAILABLE TO THIRD PARTIES WITHOUT THE PRIOR WHETTEN CONSENT BY COOLING TOWER DEPOT INC. ANY AND ALL PROPRIETARY RIGHTS TO THIS INFORMATION AND DESIGN ARE THE SOLE PROPERTY OF COOLING TOWER DEPOT INC.						INTER OF	REV.	DRWWING
			REV.	REVISION DESCRIPTION	DESIGNED BY:	CHECKED BY:	APPROVED BY:	DATE:	COOLING TOWER DEPOT, INC	ļ	0	A		
			0						651 CORPORATE CIRCLE, STE. 206	NO scylin	1	100		
			NEV: O	2						GOLDEN, CO 80401		8		
	SCALE: NO SCA	LE COMMENTS			4						720-746-1234	LE .		
Cooling Tower Depot 651 Corporate Circle Golden, CO 80401 Toll Free 877.243.3945 Phone: 720.746.1234 Fax: 720.746.1110														



DE-120 Blade Drift Eliminator

C. <u>Chemical</u>

Resistance to Grease, Fats & Oils	Excellent	ASTM D722-45
Resistance to Acids	Excellent	ASTM D543
Resistance to Alkalies	Excellent	ASTM D543

The PVC sheets shall be of uniform thickness and free from holes, air bubbles, foreign matter, undispersed raw material or other manufacturing defects which may adversely affect their performance.

D. Drift Modules

- 1. The eliminators shall be the blade multipass type with end caps to provide extra structural integrity for beam strength and durability.
- 2. The drift modules shall be able to span a minimum 6 ft. at design conditions with a minimum of deflection.
- 3. The eliminators shall be of the nesting type to insure a seamless installation and prevent bypass of the drift droplets.
- E liminators used in cross-flow applications must be designed with special drainage to insure the captured drift droplets are not reintrained into the air stream.
- 5. The eliminators shall be fitted into the interior of the tower to prevent drift in excess of 0.005% of the inlet water-flow rate and guaranteed for all operating conditions.
- 6. The mass drift quantity shall be determined by the CTI STD-140 HBIK drift test code or the EPA method 13 A system of analysis. Drift quantity shall not exceed the guarantee of .005%
- 7. Material used for the eliminators shall be suitable for continuous operation at the maximum discharge air temperature possible.
- 8. Eliminators shall be PVC or CPVC as required by the temperature of the environment, and shall be fire resistant with a maximum flame spread rate of 15 or less according to ASTM method E-84. A certified test report showing that the cellular eliminator will meet this flame spread rate is required.
- 9. The drift modules shall measure up to 24 inches wide, 5 3/4" in depth and up to 12 ft. long.

COOLING TOWER	AND LOCATION:	THIS DRAWING IS THE SOLE PROPERTY OF COOLING TOWER DEPOT INC. USE SHALL BE LIMITED TO THE PROJECT FOR WHICH IT IS INTENDED. NO REPRODUCTION SHALL BE MADE NOR SHALL THIS INFORMATION BE MADE AVAILABLE TO THIRD PARTIES WITHOUT THE PROR WRITTEN CONSENT BY COOLING TOWER DEPOT INC. ANY AND ALL PROPRIETARY RIGHTS TO THIS INFORMATION AND DESIGN ARE THE SOLE PROPERTY OF COOLING TOWER DEPOT INC.							Pierwine edu	0	CONTRACTOR OF
	OW9 NAME	REV.	DESCRIPTION	DESIGNED BY:	CHECKED BY:	APPROVED BY:	DATE:	COOLING TOWER DEPOT, INC 651 CORPORATE CIRCLE, STE. 206	NO	*	A-10
	CRAWING NUMBER: JOB NUMBER: SHEET REV: A-100 1 of 1 0	1						GOLDEN, CO 80401	0 SC	=	×
	SCALE: NO SCALE COMMENTS	4						720-746-1234	ALE	-	
	· · · · ·										



DE-120 Blade Drift Eliminator

3. Installation:

The drift modules shall be installed as per the recommendation of the eliminator manufacturer and in accordance with the engineer's specification that shall include the following:

- A. The drift modules shall be carefully cut or trimmed to fit within 1/4 inch (or less) of any obstruction or sidewall to prevent air bypass.
- B. The drift modules shall be conveyed to the top of the tower by mechanical conveyor or crane. Cranes shall be used or conveyors shall be constructed as necessary to transport the media to the working level inside the tower, and the drift modules shall be moved by hand for final placement.
- C. The shaping, cutting and trimming of the drift modules may be done in the tower provided that precaution is taken by the Contractor to prevent any chips, broken pieces, or debris from falling into the media and caution that the cutting may weaken the structural integrity of the product.
- D. The drift modules are not intended to have workmen walking on them. To prevent damage or injury, the contractor shall use plywood or other suitable temporary planking.
- E. The drift modules shall be placed in the tower to provide the closest possible fit with adjacent modules without damaging the modules. The module packing arrangement shall be as recommended by the cooling tower manufacturer and shown on the installation drawings. Drift modules shall be installed such that the sheets of all modules are perpendicular to the support beams.

£						THIS DRAWING IS THE SOLE PROPERTY OF COOLING TOWER DEPOT INC. USE SHALL BE LIMITED TO THE PROJECT FOR WHICH IT IS INTENDED. NO REPRODUCTION SHALL BE MADE NOR SHALL THIS INFORMATION AR MADE AVAILABLE TO THIRD PARTIES WITHOUT THE PRIOR WRITTEN CONSENT BY COOLING TOWER DEPOT INC. ANY AND ALL PROPRIETARY REGISTE TO THIS INFORMATION AND DESIGN ARE THE SOLE PROFERITO FO COOLING TOWER DEPOT INC.						nin sor	0	DRAWING
	MODEL NO.					REVISIONS CONTRACTOR CONTRAC								NUM
					REV.	DESCRIPTION	DESIGNED BY:	CHECKED BY:	APPROVED BY:	DATE:	COOLING TOWER DEPOT, INC		(
	DWG NAME:			0						651 CORPORATE CIRCLE, STE. 206	7		<u> </u>	
				<u> </u>		<u> </u>	<u> </u>				NO	_ <u></u>	8	
	DRAWING NUMBER: JOB NUMBER:	JOB NUMBER:	MBER: SHEET REV;		÷		<u> </u>	<u> </u>			GOLDEN, CO 80401	s "		<u> </u>
ă	A-100		1 . 1	0	-		<u> </u>	<u> </u>			GOEDEN, OO DOHOT	õ	2	
<u>9</u>	SCALE: NO SCA				- 3		<u> </u>				720-746-1234	₽		
	NU SCA				4							m		
Cooling Tower Depot 651 Corporate Circle Golden, CO 80401 Toll Free 877,243,3945 Phone: 720,746,1234 Fax: 720,746,1										111	0			
Cooling lower Depot 65 Corporate CI				rcle	e Golden, CO 8040 10	i Free	8/1.2	43.39	45	none: /20./46.1234 Fax: /20.	/40	.	U	



COOLING TOWER

